

To: scott.hansen@millelacsband.com[scott.hansen@millelacsband.com]; Restaino, Mark[restaino.mark@epa.gov]
From: Brandon, Jeffery (MPCA)
Sent: Thur 4/10/2014 3:11:20 PM
Subject: Izatys

Just an FYI. I received a call from the folks at Izatys asking about AST set back requirements. They plan to install AST's and run piping out to the end of the dock for a dispenser. I could not give them accurate answers since they did not know what type of tanks they would purchase and the set back distance depends on the tank type. I did mention that they should follow PEI 1000 and all SPCC rules.

Jeff Brandon

Environmental Specialist

Minnesota Pollution Control Agency

525 Lake Avenue South, Suite 400

Duluth, MN 55802

218-302-6610